



Customer Outages

<i>Time of Outage</i>	<i>Time Restored</i>	<i>DURATION (MINUTES)</i>	<i>LOCATION</i>	<i>FEEDER</i>	<i>MILES</i>	<i>CAUSE</i>	<i>No of Cust Out</i>
2/3/2012 4:44:00 AM	2/3/2012 8:25:00 AM	221	Veteran's Memorial Cemetery to Taco Bell Sumay	P002	6	OVERHEAD CONDUCTORS	12
2/3/2012 3:24:00 PM	2/3/2012 3:25:00 PM	1	Talofoto Baza Gardens, Ipan Talofoto	P262	13.9	FAULTS DUE TO VEGETATION CONTACTING POWER LINES	1481
2/5/2012 1:36:00 AM	2/5/2012 1:37:00 AM	1	Agana, Afame, Ordot/Chalan Pago	P250	22.3	UNDER FREQUENCY LOAD SHEDDING	2310
2/5/2012 1:36:00 AM	2/5/2012 1:37:00 AM	1	Dededo Village	P088	15.8	UNDER FREQUENCY LOAD SHEDDING	2863
2/5/2012 1:36:00 AM	2/5/2012 1:38:00 AM	2	Pulantat Yona to Togcha Cemetery	P301	9.3	UNDER FREQUENCY LOAD SHEDDING	333
2/5/2012 1:36:00 AM	2/5/2012 1:38:00 AM	2	Tamuning Old Island Equipment to Northgate Pay-Less	P201	3.7	UNDER FREQUENCY LOAD SHEDDING	1011
2/5/2012 1:36:00 AM	2/5/2012 1:39:00 AM	3	Pulantat, Yona Village, Pago bay to Mangilao Public Health	P294	13.2	UNDER FREQUENCY LOAD SHEDDING	380
2/5/2012 1:36:00 AM	2/5/2012 1:39:00 AM	3	Tamuning GPO Area	P204	3.4	UNDER FREQUENCY LOAD SHEDDING	656


 Simon Camacho,
 PSCC Manager

Monday, February 06, 2012