



**GENERATOR OUTAGES**

<i>Generators</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
DEDEDO CT 01	DEDEDO	12/29/2010 3:24:00 PM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Unit tripped 87G generator protection relay while performing weekly test run.
TENJO DSL 06	TENJO	10/26/2011 1:01:00 PM			Generator Breaker	11	GENERATOR	Diesel operator - Gogo - tagged out unit # 6 - Crew will be replacing the main generator bearings.
TANGO 01	TANGUISSON	11/28/2011 6:44:00 AM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Unit tagged out to troubleshoot excessive generator H2 gas usage.
TENJO DSL 05	TENJO	11/30/2011 7:23:00 AM	11/30/2011 8:25:00 AM	62	Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	UNIT TAGGED OUT SO CREWS CAN REPLACE INSTRUMENT DEVICE FOR CYLINDER TEMPERATURE INDICATOR ASPER DAVE AFAISON ON 11/30/2011 AT 0825HR INSTRUMENT REPLACEMENT COMPLETED.
CABRAS 04	CABRAS	11/30/2011 8:33:00 AM	12/1/2011 4:10:00 AM	1177	Generator Breaker	12	PRIME MOVER	Replacing piston for cylinder #5, Ben Diaz.

Vicente N. Mesa,  
P.E. PSCC

Thursday, December 01, 2011



**TRANSMISSION/SUB TRANSMISSION OUTAGES**

<i>Lines</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
X194	TENJO	3/15/2011 3:20:00 PM			Line Breaker	24	POWER TRANSFORMER	Breaker X-194 open to isolate the T-36 xfmer due to a leak.
X048	AGANA	7/23/2011 9:31:00 AM			Line Breaker	63	PUBLIC/ CUSTOMER ACCOMODATION	Navy DZSP-21 will be refurbishing the T-009 xfmer. See cr# 2011-123. Naval Hospital will be on the P-282 ckt.
X314	OROTE	9/23/2011 1:54:00 PM			Line Breaker	10	CUSTOMER EQUIPMENT FAILURES	34.5 KV BREAKER FOR T-13 TRANSFORMER (DZSP21 CUSTOMER'S), PENDING INSPECTION ON THE TRANSFORMER, DUE TO LOCK OUT WILL NOT RESET.
X336	COLD STORAGE	11/15/2011 7:03:00 AM			Line Breaker	60	CONSTRUCTION	X-336 bkr normally open. Awaiting auto re-closer. Breaker was used to back feed Cold storage.
H306	CABRAS	11/30/2011 8:47:00 AM	11/30/2011 11:19:00 AM	152	Line Breaker	61	PREVENTIVE MAINTENANCE	C/R 2011 - 220 , TO ALLOW SUBSTATION CREW'S PERFORM PREVENTIVE MAINTENANCE.
X054	AGANA	12/1/2011 6:47:00 AM			Line Breaker	60	CONSTRUCTION	Switch out on clearance request 2011-237, Contractors changing out X-53 Bus 3 Disc's.

Vicente N. Mesa,  
P.E. PSCC

Thursday, December 01, 2011



X053	AGANA	12/1/2011 6:47:00 AM		Line Breaker	60	CONSTRUCTION	Switch out on clearance request 2011-237, Contractors changing out X-53 Bus 3 Disc's.
X209	TAMUNING	12/1/2011 6:48:00 AM		Line Breaker	60	CONSTRUCTION	Switch out on clearance request 2011-237, Contractors changing out X-53 Bus 3 Disc's.
X051	AGANA	12/1/2011 6:48:00 AM		Line Breaker	60	CONSTRUCTION	Switch out on clearance request 2011-237, Contractors changing out X-53 Bus 3 Disc's.
X246	BARRIGADA	12/1/2011 6:50:00 AM		Line Breaker	60	CONSTRUCTION	Switch out on clearance request 2011-237, Contractors changing out X-53 Bus 3 Disc's.

Vicente N. Mesa,  
P.E. PSCC

Thursday, December 01, 2011