



GENERATOR OUTAGES

<i>Generators</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
DEDEDO CT 01	DEDEDO	12/29/2010 3:24:00 PM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Unit tripped 87G generator protection relay while performing weekly test run.
TENJO DSL 06	TENJO	10/26/2011 1:01:00 PM			Generator Breaker	11	GENERATOR	Diesel operator - Gogo - tagged out unit # 6 - Crew will be replacing the main generator bearings.
TANGO 01	TANGUISSON	12/28/2011 4:17:00 PM	2/6/2012 2:20:00 PM	57483	Generator Breaker	74	OVER-GENERATION	Tanguisson gen # 1 off line - due to over generation.
CABRAS 02	CABRAS	1/8/2012 12:01:00 AM			Generator Breaker	61	PREVENTIVE MAINTENANCE	Unit undergoing scheduled major overhaul for 40 days (08 Jan. 2012 to 16 Feb. 2012).
TANGO 01	TANGUISSON	2/6/2012 2:20:00 PM			Generator Breaker	61	PREVENTIVE MAINTENANCE	Unit tagged out for, Turbine cleaning. W/C S. santos.


 Simon Camacho
 PSCC Manager(A)



TRANSMISSION/SUB TRANSMISSION OUTAGES

<i>Lines</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
X194	TENJO	3/15/2011 3:20:00 PM			Line Breaker	24	POWER TRANSFORMER	Breaker X-194 open to isolate the T-36 xfmer due to a leak.
X048	AGANA	7/23/2011 9:31:00 AM			Line Breaker	63	PUBLIC/ CUSTOMER ACCOMODATION	Navy DZSP-21 will be refurbishing the T-009 xfmer. See cr# 2011-123. Naval Hospital will be on the P-282 ckt.
X336	COLD STORAGE	11/15/2011 7:03:00 AM			Line Breaker	60	CONSTRUCTION	X-336 bkr normally open. Awaiting auto re-closer. Breaker was used to back feed Cold storage.
X100	TANGO	12/28/2011 4:17:00 PM			Line Breaker	74	OVER-GENERATION	Tanguisson unit # 1 taken off line - due to over generation. W/C N.Malano
H330	CABRAS	1/8/2012 12:01:00 AM			Line Breaker	61	PREVENTIVE MAINTENANCE	Unit undergoing scheduled major overhaul for 40 days (08 Jan. 2012 to 16 Feb. 2012).
H322	CABRAS	1/8/2012 12:01:00 AM			Line Breaker	61	PREVENTIVE MAINTENANCE	Unit undergoing scheduled major overhaul for 40 days (08 Jan. 2012 to 16 Feb. 2012).


 Simon Camacho
 PSCC Manager(A)



H750	PITI	2/6/2012 9:15:00 AM	2/6/2012 9:22:00 AM	7	Line Breaker	63	PUBLIC/ CUSTOMER ACCOMODATION	Switch out T-9 Xfmr GIS, Requested by MEC.
H740	PITI	2/6/2012 9:15:00 AM	2/6/2012 9:22:00 AM	7	Line Breaker	63	PUBLIC/ CUSTOMER ACCOMODATION	Switch out T-9 Xfmr GIS, Requested by MEC.

*Simon Camacho
PSCC Manager(A)*

Tuesday, February 07, 2012