



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN  
P.O. BOX 2977 HAGATNA, GUAM U.S.A. 96932-2977

**August 19, 2010**

## **AMENDMENT NO.: I**

### **REQUEST FOR PROPOSAL NO.: GPA-RFP-10-010 FOR ENGINEERING PLANNING SERVICES**

Prospective Offerors are hereby notified of the following responses to questions submitted by C.H. Guernsey & Company.

#### **Dated August 10, 2010 Question:**

##### **QUESTION:**

- 1.) Does the project include the development of a load forecast or does GPA have a load forecast we are to use?**

##### **ANSWER:**

GPA has a current forecast and is in the process of hiring services to perform short and long-term forecasts for energy, demand, and fuel.

##### **QUESTION:**

- 2.) Does GPA have a planning reserve requirement they want to use or should the project develop a planning reserve requirement?**

##### **ANSWER:**

GPA has used a planning criteria for generation reserve which is N-1 or the amount of the largest unit on the system (66 MW). In addition, GPA has adopted the reliability criteria of an equivalent of 1 day in 4.5 years loss of load. These have been used in planning studies approved by Guam Public Utilities Commission.

##### **QUESTION:**

- 3.) Will Guernsey be using a GPA license for Strategist and PICES, or should those license fees be included in the project?**

**ANSWER:**

GPA will not expand license to include contractors. GPA will run models and the program can be made available for contractors while onsite. GPA does expect contractors to provide suggestions on how to model and review results.

**In addition to this, offerors are advised all questions must be submitted no later than August 27, 2010 by 4:00PM. GPA will complete responses to questions by September 3, 2010.**

All other Terms and Conditions in the RFP package shall remain unchanged and in full force.



*per* JOAQUIN C. FLORES, P.E.  
General Manager