



GENERATOR OUTAGES

<i>Generators</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
CABRAS 02	CABRAS	5/10/2008 10:22:00 PM			Generator Breaker	62	REPAIR	Scheduled shut down for unit # 2 for boiler over haul.
MACHECHE CT	MACHECHE	5/23/2008 5:30:00 PM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Turbine mounting bolts rusted off. Unit tagged out
PULANTAT DSL 01	PULANTAT	5/27/2008 2:08:00 PM			Generator Breaker	11	GENERATOR	Faulty voltage regulator. Unit was tagged out.

TRANSMISSION/SUB TRANSMISSION OUTAGES

<i>Lines</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
X020	PITI	5/31/2008 10:05:00 AM	6/2/2008 11:55:00 AM	2,990	Line Breaker	47	BIRDS	3 ea damage post type insulator - caused by 1 ea big bird. 6/2/08 1155 DDE jumpers tied back in. X-20 bkr closed

*Vicente Mesa, P.E.
PSCC Manager*

Tuesday, June 03, 2008