



GENERATOR OUTAGES

<i>Generators</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
CABRAS 02	CABRAS	5/10/2008 10:22:00 PM			Generator Breaker	62	REPAIR	Scheduled shut down for unit # 2 for boiler over haul.
MACHECHE CT	MACHECHE	5/23/2008 5:30:00 PM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Turbine mounting bolts rusted off. Unit tagged out
TALOFOFO DSL 02	TALOFOFO	6/16/2008 7:08:00 AM			Generator Breaker	11	GENERATOR	Unit tagged out due to faulty PF controller.

TRANSMISSION/SUB TRANSMISSION OUTAGES

<i>Lines</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
X213	TAMUNING	6/16/2008 10:45:00 AM			Line Breaker	61	PREVENTIVE MAINTENANCE	PM work to be done. Charging motor for H-606 bkr burnt out. Unable to restore T-600. Sustation crew trying to repair
H606	TAMUNING	6/16/2008 10:45:00 AM			Line Breaker	61	PREVENTIVE MAINTENANCE	PM work to be done. Charging motor for H-606 bkr burnt out. Unable to restore T-600. Sustation crew trying to repair

Vicente Mesa, P.E.
Vicente Mesa, P.E.
PSCC Manager

Tuesday, June 17, 2008



X143	PULANTAT	6/17/2008 4:12:00 AM	6/17/2008 6:07:00 AM	115	Line Breaker	65	UNKNOWN	SEL show's approx 4.29 miles. No findings. Targets: Time target.
X123	TALOFOFO	6/17/2008 4:12:00 AM	6/17/2008 6:07:00 AM	115	Line Breaker	65	UNKNOWN	SEL shows approx 1.1 miles. No findings. Targets: Inst. to grd, zone1


Vicente Mesa, P.E.
PSCC Manager

Tuesday, June 17, 2008