



**GENERATOR OUTAGES**

<i>Generators</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
CABRAS 02	CABRAS	5/10/2008 10:22:00 PM	6/25/2008 3:02:00 AM	65,080	Generator Breaker	62	REPAIR	Scheduled shut down for unit # 2 for boiler overhaul.
MACHECHE CT	MACHECHE	5/23/2008 5:30:00 PM			Generator Breaker	13	AUXILIARY SYSTEMS (provide details)	Turbine mounting bolts rusted off. Unit tagged out

**TRANSMISSION/SUB TRANSMISSION OUTAGES**


<i>Lines</i>	<i>Locations</i>	<i>Time Out</i>	<i>Time In</i>	<i>DURATION (MINUTES)</i>	<i>CLEARING DEVICE</i>	<i>CAUSE Code</i>	<i>Cause Description</i>	<i>COMMENT</i>
H760	PITI	6/24/2008 12:58:00 PM	6/24/2008 3:10:00 PM	132	Line Breaker	65	UNKNOWN	No findings, Targets: SOPS zone 2, C phase to grd. distance = 8.95 miles
H710	PITI	6/24/2008 12:58:00 PM	6/24/2008 3:10:00 PM	132	Line Breaker	65	UNKNOWN	No findings, Targets: SOPS zone 2, C phase to grd. distance = 8.95 miles .
H502	HARMON	6/24/2008 12:58:00 PM	6/24/2008 3:09:00 PM	131	Line Breaker	65	UNKNOWN	No findings, Targets: Instan, zone 1, C phase to grd. distance = 2.02 miles .

  
 Vicente Mesa, P.E.  
 PSCC Manager

Wednesday, June 25, 2008



X020	PITI	6/24/2008 4:48:00 PM	6/24/2008 5:39:00 PM	51	Line Breaker	67	Manual operation of device due to equipment failure	To repair PT's on buss # 5.
X245	BARRIGADA	6/25/2008 1:05:00 AM	6/25/2008 2:17:00 AM	72	Line Breaker	65	UNKNOWN	No Finding, Targets: Z-1 Inst to gnd, distance= 2.40 miles
X173	GAA	6/25/2008 1:05:00 AM	6/25/2008 2:17:00 AM	72	Line Breaker	65	UNKNOWN	No Findings. Targets: Z-1 Inst to gnd, distance= 1.50 miles
X263	SAN VITORES	6/25/2008 5:27:00 AM	6/25/2008 7:19:00 AM	112	Line Breaker	20	STATIC WIRE	Down static line @ PP#PP-65-6A
X214	TAMUNING	6/25/2008 5:27:00 AM	6/25/2008 7:19:00 AM	112	Line Breaker	20	STATIC WIRE	Down static line @ PP#PP-65-6A

  
 Vicente Mesa, P.E.  
 PSCC Manager  
 Wednesday, June 25, 2008