




## Customer Outages

<i>Time of Outage</i>	<i>Time Restored</i>	<i>DURATION (MINUTES)</i>	<i>LOCATION</i>	<i>FEEDER</i>	<i>MILES</i>	<i>CAUSE</i>	<i>No of Cust Out</i>
6/10/2008 9:16:00 PM	6/10/2008 10:07:00 PM	51	Piti Nimitz Hill	P005	6.6	FAULTS DUE VEGTATION CONTACTING POWER LINES	331
6/10/2008 10:10:00 PM	6/10/2008 10:12:00 PM	2	Apra Agat	P221	4.5	SNAKES	1677

  
Vicente Mesa, P.E.  
PSCC Manager

Wednesday, June 11, 2008